



Government of India

**MINISTRY OF HEALTH & FAMILY WELFARE
National AIDS Control Organization (NACO)**

Government of India

Through

Strategic Alliance Management Services Pvt. Ltd. (SAMS)

B01-B03, Vardhman Diamond Plaza, Community Centre,

D.B. Gupta Road, Paharganj, New Delhi – 110 055



International Competitive Bidding (ICB)

Invitation for Bids (IFB)

for

E-PROCUREMENT of Walk-in-Cold Room and DG Set – 10 KVA

(IFB No. SAMSPL/17-18/ET/5)

AMENDMENT No. 5 dated 27/9/2017

As per Bid Data Sheet ITB Para 7.2, the Pre-Bid Meeting was held on 10/7/2017 at 1500 Hrs. Subsequently, the due date for submission and opening of bids and other associated dates were last amended vide Amendment No. 4 dated 20/9/2017.

Further, the Minutes of Pre-Bid Meeting and responses / amendments against clarifications sought by prospective bidders have been issued on 27/9/2017. Now, as referred in said Minutes of Pre-Bid Meeting, and pursuant to the ITB Para 8, the following Addendums are being issued

S. N.	Para / Clause reference in the Bid Document	As Provided	As Amended
1	Section VII – Schedule of Requirements – Technical Specifications – Schedule-1: Walk-in-Cold Room: Sr. No. A. 7	<u>Refrigerant: R 22 A</u>	Refrigerant: R 410a or R 134a.
2	Section VII – Schedule of Requirements – Technical Specifications – Schedule-1: Walk-in-Cold Room: Sr. No. B.5	<u>Panel Surface Material:</u> Minimum 80mm, PUF Panel with both sides PPGI of 0.7mm thickness	<u>Panel Surface Material:</u> Minimum 80mm, PUF Panel with both sides PPGI of 0.5mm thickness.
3	Section VII – Schedule of Requirements – Technical Specifications – Schedule-1: Walk-in-Cold Room: Sr. No. B.6	<u>Floor Insulation:</u> Minimum 80mm PUF panel with outer side 0.7mm PPGI & Inner side marine Ply of 9mm thickness & Aluminum Chequered plate of 2mm	<u>Floor Insulation:</u> Minimum 80mm PUF panel with outer side 0.5mm PPGI & Inner side marine Ply of 9mm thickness & Aluminum Chequered plate of 2mm
4	Section VII – Schedule of Requirements – Technical Specifications – Schedule-1: Walk-in-Cold Room: Sr. No. B.13	Data Logger & Display: <ul style="list-style-type: none"> Display: LED 	Data Logger & Display: <ul style="list-style-type: none"> Display: LED/LCD
5	Section VII – Schedule of Requirements – Technical Specifications – Schedule-1: Walk-in-Cold Room: Sr. No. B.4	<u>Panel Thickness:</u> Minimum 80mm. PUF (Poly Urethane Foam), Density $40 \pm 2 \text{ kg / m}^3$ & PUF blowing agent-141B (CFC free)	<u>Panel Thickness:</u> Minimum 80mm. PUF (Poly Urethane Foam), Density $40 \pm 2 \text{ kg / m}^3$ & CFC Free PUF blowing agent.

S. N.	Para / Clause reference in the Bid Document	As Provided	As Amended
6	Section VII – Schedule of Requirements – Technical Specifications – Schedule-1: Walk-in-Cold Room: Sr. No. B.3	<u>Panel Construction:</u> Prefabricated sandwich panels with cam toggle-type fastener fitted & self-locking PVC gaskets fitted on all sides of Wall, Ceiling, and Floor Panels. L Shaped separate corner fitted with cam toggle-type fastener. All panels fit together by cam toggle-type fastener. Panel with Ribs on both side panel surface materials to increase the strength. Wall, ceiling & floor all get together by the mentioned arrangements. Wall panel having Only Cam Toggle-Type fastener fitting, No Flashings and Riveting on Panel	<u>Panel Construction:</u> Prefabricated sandwich panels with cam toggle-type fastener fitted & self-locking PVC gaskets fitted on all sides of Wall, Ceiling, and Floor Panels. L Shaped separate corner fitted with cam toggle-type fastener. All panels fit together by cam toggle-type fastener. Panel with Ribs on both side panel surface materials to increase the strength. Wall, ceiling & floor all get together by the mentioned arrangements. Wall panel having Only Cam Toggle-Type fastener fitting.
7	Section VII – Schedule of Requirements – Technical Specifications – Schedule-2: Diesel Generator (DG) Set – 10 KVA: Sr. No. B.1 (a)	The Alternator shall be self-excited and self-regulated of specified KVA rating in single phase at 240 Volt, 50 Hz, 1500 RPM and 0.8 power factor (PF) and shall conform to IS:13364 (Part 1):1992 (reaffirmed 2003) . The alternators shall be of brush less type with VG-1 Grade or better grade of voltage regulation.	The requirement is being amended as under: The Alternator shall be self-excited and self-regulated of specified KVA rating in three phase at 440 Volt , 50 Hz, 1500 RPM and 0.8 power factor (PF) and shall conform to IS:13364 (Part 1):1992 (reaffirmed 2003) . The alternators shall be of brush less type with VG-1 Grade or better grade of voltage regulation
8	Section VII – Schedule of Requirements – Technical Specifications – Schedule-2: Diesel Generator (DG) Set – 10 KVA: Sr. No. B.2 (d) 1.	Fuel tank with capacity for 12 hours continuous running at full load.	Fuel tank with capacity for minimum 8 hours continuous running at full load
9	Section VIII – General Conditions of Contract – GCC Para 16.5 and Section IX – Special Conditions of Contract	GCC 16.5: In the event that the Purchaser fails to pay the Supplier any payment by its due date or within the period set forth in the SCC, the Purchaser shall pay to the Supplier interest on the amount of such delayed payment at the rate shown in the SCC, for the period of delay until payment has been made in full, whether before or after judgment or arbitrage award SCC of GCC 16.5: The payment-delay period after which the Purchaser shall pay interest to the supplier shall be 90 days. The interest rate that shall be applied is 4% per annum for	The Clause 16.5 stands deleted

S. N.	Para / Clause reference in the Bid Document	As Provided	As Amended
		payments in Indian currency. For foreign currency per annum interest rate will be LIBOR three month rate for specific currency as prevailing on date of NOA.	

Further, Bidders' attention is drawn to the last para of ITB Para 19.3 related to validity of Bid Security. In view of the amendment/extension in dates as above, the bid submitted by bidders is required to be valid up to 31 Jan, 2018. Therefore, the bid security submitted by bidders pursuant to ITB Para 19 is required to be valid up to 28 Feb, 2018.

All other terms and conditions of the Bid Document shall remain unchanged

For and on behalf of
Strategic Alliance Management Services Pvt. Ltd.



(Satya Verma)
 General Manager (Procurement)